



March 13, 2014

LEDGEVIEW PRECAST CONCRETE, INC.
ALLEN E. FREUND
N6672 COUNTY TRUNK UU
FOND DU LAC WI 54937

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.
Product Name: FILTER CANISTER
Model Number(s): NONE
[34 IN. L.L.; MAX. DEPTH OF BURY = 96 IN.]
Product File No: 20140040

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.**

This approval supersedes the approval issued on 3/16/2010 under product file number 20100113.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Two inch PVC cast in riser for electrical wiring.
 - Press Seal "Cast-A-Seal".
 - Dual inlets at end of tank with an access opening above one inlet and an observation opening over the other inlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Tank bedding and burial depth: A minimum of 4 in. of $\frac{3}{4}$ in. clear stone overlying a firm uniform base. Bedding should be level around the perimeter and concave at the middle. For tank burial depths greater than 48 in., contact manufacturer for alternate installation instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov